

## TEST CERTIFICATE

Certificate Nr: EEA – 1700 – 0063

The related resistance to fire test was carried out at **Efectis Era Avrasya Test Laboratory** on 14.07.2017 in accordance with EN 1634-1:2014 standard for the product as described below:

### “ YDSK-002 ” STEEL ACCESS DOOR

*Single Leaf*

FIRE RESISTANCE CLASSIFICATION	
Direction: Opening away from the fire	E 90, EI <sub>2</sub> 60, EI <sub>1</sub> 30
Direction: Opening into the fire	E 90

Placed on the market by


**PİDOMETAL ÇELİK KAPI PVC KAPI PEN.DOĞ.İNŞ.EML.OTO.GIDA TEKS.SAN. VE TİC.LTDŞTİ.**  
Eski Yuva Yolu Üzeri Yuva Mah. 3702/1 Sokak No: 8/1 Yenimahalle, ANKARA, TURKEY

And Produced In the Factory

**PİDOMETAL ÇELİK KAPI PVC KAPI PEN.DOĞ.İNŞ.EML.OTO.GIDA TEKS.SAN. VE TİC.LTDŞTİ.**  
Eski Yuva Yolu Üzeri Yuva Mah. 3702/1 Sokak No: 8/1 Yenimahalle, ANKARA, TURKEY

This test certificate is a declaration of the test results and does not represent any type approval or certification of the product. All details related to product specifications and field of application are described in the report **EEA – 17– 080**.

This certificate is initially valid until 20<sup>th</sup> July 2018 providing that no significant modifications are made in technical specification of the specimen and related test and classification standards.



Onur DAĞ  
Operation Manager

